

## LIST OF EQUIPMENT AND REQUIRED DEVICES

This list can be found in the CT DPH Cross Connection Control manual and serves a guidance for equipment that is typically encountered during a Cross Connection Inspection.

**Device Abbreviations:**

- A.G. – Air Gap
- A.V. – Air Vent Type Backflow Preventer
- D.C.V.A. – Double Check Valve Assembly
- R.P.D. – Reduced Pressure Principle Backflow Preventer
- V.B. – Vacuum Breaker (Atmospheric, Pressure, Hose Bibb, etc.)

EQUIPMENT	A.G.	R.P.D.	A.V.	V.B.	D.C.V.A.
Aspirator				X	
Auxiliary Water System	X				
Bedpan Washer				X	
Boiler (chemicals added)		X			
Boiler (no chemicals)		X	X		
Carbonator (soda machine)			X		
Cash Wash		X			
Chlorinator or Other Chemical Injection System		X			
Cooling Tower	X	X			
Dental Equipment				X	
Film Processing Equipment				X	
Fire Sprinkler System (chemicals added)		X			
Fire Sprinkler System (w/Siamese connection, no chemicals)					X
Flush Valve Toilet				X	
Garbage Can Washer	X			X	
Garbage Disposal	X			X	
Gas Storage (under pressure)		X			
Hair Wash Sink				X	
Heat Exchanger (chemicals added – single wall)		X			
Heat Exchanger (no chemicals – single wall)		X	X		
Heat Exchanger – Vented Double Wall					
Hemodialysis Unit	X	X		X	
Ice Machines	X			X	
Irrigation/Lawn Sprinkler (chemicals added to system)		X			
Irrigation/Lawn Sprinkler (no chemicals)				X	
Laboratory Sinks				X	
Laundry Machines	X			X	
Marina, Dock		X		X	
Plating or Dye Tanks, Vats	X	X			
Pressurized Water System (ship)		X			
Sewage Pumps/Sewage – Connected Equipment	X				
Service Line (toxic or objectionable substance)		X			
Soap Injector				X	
Solar System (chemicals added)		X			
Solar System (no chemicals)			X	X	
Steam Generating Equipment		X			
Storage Tank (fire protection, no chemicals)		X	X		
Submerged Inlet				X	
Tank Truck (lawn care, sweeper)	X	X		X	
Water Cooled Equipment	X			X	
Water Treatment Equipment		X	X		
X-Ray Developer				X	